



F-GAS AND ECODESIGN:

INFLUENCES OF EU LEGISLATION
ON ITALIAN INDUSTRY



9 maggio 2016 / 9 May 2016

09.00 – 18.00

Hotel NH Laguna Palace

Mestre (VE)

F-Gas And Ecodesign: Influences Of EU Legislation On Italian Industry

Focus on Lot 1

By Dina Koepke
Director Governmental Affairs
Emerson Climate Technologies Europe
Mestre, 9th of May 2016

Agenda

- Ecodesign regulations HVACR
- Ecodesign regulations – market influence and requirements
 - ENTR lot 1 - professional refrigerated storage cabinets, blast cabinets, condensing units & process chillers
- Ecodesign and F-gas regulation
- F-Gas regulation and its ripple effect
- Manufacturers' challenges – qualification, design, testing, manufacturing
- Industry response to legislative changes

EU HVACR Ecodesign Regulations


Direct Impact – Legal Document # - Limited Application

- ENER Lot 1 (EU) No 813/2013 Space & Combination Heaters
- ENER Lot 2 (EU) No 813/2013 Water Heaters & Hot Water Storage Tanks
- ENER Lot 10 (EU) No 206/2012 Air Conditioners & Comfort Fans
- ENER Lot 11 (EU) No 327/2011 Fans Driven By Motors – Review
- ENER Lot 11 (EC) No 640/2009 Electric Motors (Not For Compressors) – Under Review
- ENER Lot 12 Refrigerated Commercial Display Cabinets - Consultation Forum (CF) / Impact Assessment (IA)
- ENER Lot 21 Air Heating Products, Cooling Products & High Temp Process Chillers – Scrutiny Period – Coming into Force Summer 2016
- ENER Lot 30 Special Motors (Not For Compressors) & Var. Speed Drives
- ENER Lot 31 Compressors (Not For Refrigeration Purposes)
- ENER Lot 33 Smart Appliances

- ENTR Lot 1 (EU) No 1095/2015 Professional Refrigerated Storage Cabinets, Blast Cabinets, Condensing Units & Process Chillers


ENTR Lot 1 & ENER Lot 21

Chillers are in both regulations



Chillers

Load and Temperature Profiles



Process Chillers – SEPR Analysis

Minimum Efficiency Performance Standards (MEPS)

ENTR Lot 1 MT and LT Process Chillers: SEPR

| | Cooling Capacity | MEPS Tier-1 | MEPS Tier-2 |
|-----------------|------------------|-------------|-------------|
| LT air-cooled | < 200 kW | 1,48 | 1,7 |
| | ≥ 200 kW | 1,6 | 1,84 |
| MT air-cooled | < 300 kW | 2,24 | 2,58 |
| | ≥ 300 kW | 2,8 | 3,22 |
| LT water-cooled | < 200 kW | 1,82 | 2,09 |
| | ≥ 200 kW | 2,1 | 2,42 |
| MT water-cooled | < 300 kW | 2,86 | 3,29 |
| | ≥ 300 kW | 3,8 | 4,37 |

Additional ENTR Lot 1: Bonus for GWP < 150 -> Tier-1 / Tier-2: 10 %

ENER Lot 21 HT Process Chillers: SEPR

| | Cooling Capacity | MEPS Tier-1 | MEPS Tier-2 |
|--------------|------------------|-------------|-------------|
| air-cooled | < 400 kW | 4,5 | 5,0 |
| | ≥ 400 kW | 5,0 | 5,5 |
| water-cooled | < 400 kW | 6,5 | 7,0 |
| | ≥ 400 kW | 7,5 | 8,0 |
| | ≥ 1500 kW | 8,0 | 8,5 |

ENTR Lot 1 Condensing Units Requirements (CE Marking)


| | COP | SEPR |
|--|------------|------------|
| Low Temp (T evap -35°C) | 0.1 - 2kW | 2 - 20kW |
| Medium Temp (T evap -10°C) | 0.2 - 5kW | 5 - 50kW |
| T amb | 32°C | |
| T amb (D) 5°C | | part load |
| T amb (C) 15°C | | part load |
| T amb (B) 25°C | | part load |
| T amb (A) 32°C | | full load |
| degradation for fixed and staged capacity at part load | | 0.25 |
| Tier 1 | 1.7.2016 | 1.7.2016 |
| Tier 2 | 1.7.2018 | 1.7.2018 |
| Bonus for GWP <150 @ Tier 1 | 15% | 15% |
| Bonus for GWP <150 @ Tier 2 | 10% | 10% |
| Rating Standard | EN 13215 | EN 13215 |
| Testing Standard | EN 13771-2 | EN 13771-2 |
| Tolerances for Market Surveillance | 10% | 10% |
| Additional Product Information Requirements | | |

Product Information Requirements:


Follow Layout from Legal Text!!

ASERCOM Condensing Unit Certification Scheme available

COP Condensing Units




SEPR Condensing Units



Market Influence ENTR Lot 1

Condensing Units



| | | |
|------------------|-----|-----|
| Total | 114 | |
| Medium Temp <5kW | | % |
| Tier 1: 7/2016 | 10 | 9% |
| Tier 2: 7/2018 | 46 | 40% |

% of condensing units
phased out by the 2
 tiers, as of today

Ecodesign and F-Gas Regulation


| Title of Product Regulation | ErP GWP Rules and F-Gas Bans | 2013 | 2014 | 2015 | 2016 | 2017 | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 | 2024 | 2025 | 2026 | 2027 | 2028 | 2029 | 2030 | |
|---|------------------------------|------|------|------|------|------|------|------|----------|------|--------|------|------|---------|------|------|------|------|------|---------------------------|
| (EU) No 327/2011: fans driven by motors 125W-500 kW | | | | | | | | | | | | | | | | | | | | Under Review |
| ENER Lot 30: motors (0,12-1.000kW) and VSDs | | | | | | | | | | | | | | | | | | | | Draft Regulation |
| (EU) No 206/2012: air conditioners ≤ 12 kW and (EU) No 813/2013: space & combination heaters ≤ 400 kW | GWP 150 Bonus | | | | | | | | 2500 GWP | | | | | 750 GWP | | | | | | |
| (EU) No 814/2013: water heaters ≤ 400 kW | | | | | | | | | 2500 GWP | | | | | | | | | | | |
| (EU) No 814/2013: water heaters ≤ 400 kW | | | | | | | | | 2500 GWP | | | | | | | | | | | |
| (EU) No 1253/2014: ventilation units | | | | | | | | | 2500 GWP | | | | | | | | | | | |
| (EU) 2015/1095: professional refrigeration products | GWP 150 Bonus | | | | | | | | 2500 GWP | | | | | | | | | | | |
| ENER Lot 12: commercial refrigeration products | Hermetically Sealed | | | | | | | | 2500 GWP | | 150 GW | | | | | | | | | Draft Regulation |
| ENER Lot 21: air heating, cooling products, high temp process | | | | | | | | | 2500 GWP | | | | | | | | | | | Scrutiny until 1st of May |
| F-Gas Regulation | Multipack centralized | | | | | | | | 2500 GWP | | 150 GW | | | | | | | | | |
| Phase Down Plus Pre-charged Imports 12% in 2015/2016 | | | | 112% | 105% | 93% | 63% | 63% | 63% | 45% | 45% | 45% | 31% | 31% | 31% | 24% | 24% | 24% | 21% | |
| Minus New Entrants Reserve: 11% | | | | 89% | 83% | 83% | 56% | 56% | 56% | 40% | 40% | 40% | 28% | 28% | 28% | 21% | 21% | 21% | 19% | |
| Minus Pre-Charged Imports 12% Today, 18% in 2030 | | | | 89% | 83% | 72% | 49% | 48% | 48% | 34% | 34% | 33% | 23% | 23% | 23% | 17% | 17% | 17% | 15% | |

F-Gas Regulation Ripple Effect


- F-Gas: Many more flammable refrigerants to consider
Condensing units will move to lowest GWP options, including A2L (eq. 1,3kg R404A) and even A3 refrigerants (eq. 0,4kg R404A)
- Ecodesign: Phase down forces to consider other refrigerants than during study and impact assessment
- Atex: Changeover of electrical components
→ equipment cost
- PED: Class move → equipment cost
- Standards: update of safety standards for use of flammable refrigerants ongoing → lengthy process

Compressor Qualification

Resource and Time Intense Process



Emerson New Product Development Process



- Full process taking several months to years
- Short-cuts depending on scope of design challenge
- Controlled pre-release for field testing
- > 100 compressors for new product development under accelerated conditions

Phases

- Theoretical assessment
- Reliability & safety pre-assessment
- Performance pre-assessment
- Reliability & safety for final release
- Performance for final release
- **Formal rating including ASERCOM certification**

Response to Legislative Changes

- Align portfolio and documentation to adhere to new rules
- Tackle Rating Standard EN13215 to adjust for impact of glide on condenser performance
- Support and participate in timely flammable refrigerant standards
 - Revision of building codes, at EU and national/regional level
- Support training & education of business partners
- Face and understand the global market situation - complexity and interdependence of regulations worldwide
- Understand and focus on LCCP, not only GWP – indirect and direct emissions
- Learn from Montreal protocol and coordinate industry efforts to have the most efficient phase-down
- National approach in market surveillance is not sufficient for level playing field
 - Support voluntary certification schemes for a more level playing field and for a possible relieve of market surveillance authorities.